

NFPA Technical Committee Document Proposal Form

Note: All proposals must be received by 5:00 p.m. EST/EDST on the published proposal closing date.

For further information on the standards-making process, please contact
Codes and Standards Administration at 617-984-7249.
For technical assistance, please call NFPA at 617-770-3000.

FOR OFFICE USE ONLY

Log #: _____

Date Rec'd _____

Please indicate in which format you wish to receive your ROP/ROC: CD ROM paper download
(Note: In choosing the download option you intend to view the ROP/ROC from our Website. No copy will be sent to you.)

Date Oct. 1, 2002 Name William King Telephone 301-504-0508, ext. 1296

Company U.S. Consumer Product Safety Commission

Address 4330 East West Highway City Bethesda State MD Zip 20814-4408

Please indicate organization represented (if any) U.S. Consumer Product Safety Commission

1. a) NFPA Document Title National Electrical Code
b) NFPA No. & Edition 70-2002 c) Section/Paragraph 210.12
2. Proposal Recommends (check one): new text revised text deleted text
3. Proposal. (Include proposed new or revised wording, or identification of wording to be deleted.) Note: Proposed text should be in legislative format, that is, use underscore to denote wording to be inserted (inserted wording) and strike-through to denote wording to be deleted (~~deleted wording~~).
(See attachment for Proposal)

4. Statement of Problem and Substantiation for Proposal. Note: State the problem that will be resolved by your recommendation. Give the specific reason for your proposal including copies of tests, research papers, fire experience, etc. If more than 200 words, it may be abstracted for publication.
(See attachment for Statement of Problem and Substantiation for Proposal)

5. This Proposal Is Original Material. Note: Original material is considered to be the submitter's own idea based on or as a result of his/her own experience, thought, or research and, to the best of his/her knowledge, is not copied from another source.

This Proposal Is Not Original Material; Its Source (if known) is as Follows: _____

This proposal represents the views of the writer and not necessarily the official position of the CPSC.

I hereby grant NFPA all and full rights in copyright to this proposal, and I understand that I acquire no rights in any publication of NFPA in which this proposal in this or another similar or analogous form is used.

Signature (Required)

William H King

PLEASE USE SEPARATE FORM FOR EACH PROPOSAL • NFPA Fax: (617) 770-3500

Mail to: Secretary, Standards Council • National Fire Protection Association
1 Batterymarch Park • PO Box 9101 • Quincy, MA 02269-9101

PROPOSAL.

Section/Paragraph: Art. 210, Part I. General, para. 210.12

Revise the section of the paragraph covering dwelling unit bedrooms as follows:

() Dwelling Unit Bedrooms. All branch circuits that supply 125-volt, single-phase, 15- and 20-ampere outlets installed in dwelling unit bedrooms shall be protected by ~~an arc-fault circuit interrupter listed to provide protection to the entire branch circuit~~ a listed arc-fault circuit interrupter, branch/feeder type, or a listed arc-fault circuit interrupter, outlet branch circuit type. The arc-fault circuit interrupter, outlet branch circuit type, shall be the outlet closest to, and within 3.0 m (10 ft) of the overcurrent device as measured along the branch circuit conductors.

STATEMENT OF PROBLEM AND SUBSTANTIATION FOR PROPOSAL.

The existing requirement at 210.12 covering dwelling unit bedrooms has been modified to include both types of arc-fault circuit interrupters (i.e., branch/feeder type and outlet branch circuit type) that are to be covered by expanded definitions.

Although AFCI devices currently available are incorporated within circuit breakers, AFCI devices have been listed that are incorporated into outlet devices. While only AFCI/circuit breakers can de-energize the entire branch circuit, listed AFCI/outlet devices can be applied in applications where fuses are provided as the branch circuit overcurrent protection devices. In addition, listed AFCI/outlet devices have been investigated and listed as an outlet branch circuit type with expanded arc detection capabilities, including sensing certain arcing conditions upstream of the AFCI/outlet device location, and sensing broader arcing conditions downstream of the AFCI/device location. These safety devices that provide the broadest range of fire protection to the occupants of dwellings.