



MEETING LOG

SUBJECT: ANSI/CSA JOINT TECHNICAL SUBCOMMITTEE (TSC) MEETING ON BOILERS, September 29, 2025

FY 25 OP PLAN ENTRY: Gas Appliances - CO Sensors

DATE OF MEETING: 9/29/2025

LOCATION OF MEETING: Virtual

CPSC STAFF FILING MEETING LOG: Ronald A. Jordan

FILING DATE: 9/29/2025

CPSC ATTENDEE(S): Ronald Jordan, ESMC

NON-CPSC ATTENDEE(S): Contact babak.owlam@csagroup.org for the full attendee list.

Summary of Meeting:

The boiler Technical Subcommittee (TSC) met to discuss several standards development issues associated with ANSI Z21.13- 8th edition, Standard for Gas-fired Low-Pressure Steam and Hot Water Boiler. The TSC working group discussed and resolved the following action items:

The TSC discussed RFC#4 (inclusion and installation of a residential CO alarm concurrent with each new boiler purchase and installation) developed by the boiler CO Sensor Working Group (WG). The TSC voted on and approved RFC#4. The TSC also voted on and approved that all TSC approved be sent forward to the TC as an amendment to the current edition of the boiler standard, ANSI Z21.13, 7th edition. The WG will continue to develop RFC#5 into a draft standard and will forward to the TSC for consideration once completed.

The TSC meeting scheduled for October 3, 2025 was canceled. The meeting adjourned at 4:00 pm.