



U.S. CONSUMER PRODUCT SAFETY COMMISSION

WASHINGTON, D.C. 20207

Record of Commission Action
December 8, 1982

In the Matter of: Reliance Electric Company/Federal Pacific Electric Company
(Reliance/FPE) Circuit Breakers (Restricted OS #3487)


Commissioners Present and Voting: Chairman Nancy Harvey Steorts
Commissioner Stuart M. Statler
Commissioner Sam Zagoria

Decision: Meeting in closed session on December 8, 1982, the Commission considered the disposition of the Section 15, CPSA, case concerning the Reliance/FPE circuit breakers. The Commission had discussed this matter at its meeting of September 22, 1982, and voted subsequently by ballot as to whether to authorize staff to develop evidence necessary to support the issuance of a complaint or to close the file. The result of the ballot vote did not resolve the issue: Commissioner Edith Sloan voted to develop evidence to support issuance of a complaint; Commissioners Statler and Zagoria voted to close the matter; Chairman Steorts did not vote. Therefore, this meeting was scheduled.

Following discussion, the Commission voted 3-0 to close the Section 15 case and instructed the staff to draft a CPSC press release concerning this matter to be sent to Reliance pursuant to Section 6(b), CPSA, prior to its release. Commissioner Sloan was not present, but informed the Office of the Secretary that her prior vote by ballot stands; therefore, the vote to close the case is 3-1.

The decision in this matter will be made public information upon approval and issuance of a press release.*

For the Commission:


Sadye E. Dunn
Secretary

* A Press Release was issued March 3, 1983, copy attached; Decision read into the record and incorporated in Minutes of March 9, 1983.

NEWS from CPSC

U.S. Consumer Product Safety Commission

FOR RELEASE: MARCH 3, 1983

COMMISSION CLOSES INVESTIGATION OF FPE CIRCUIT BREAKERS AND PROVIDES SAFETY INFORMATION FOR CONSUMERS

WASHINGTON, D.C. -- The Consumer Product Safety Commission announced today that it is closing its two year investigation into Federal Pacific Electric Stab-lok type residential circuit breakers. This action was taken because the data currently available to the Commission does not establish that the circuit breakers present a serious risk of injury to consumers.

The Commission investigation into Federal Pacific Electric (FPE) circuit breakers began in June, 1980, when Reliance Electric Co., a subsidiary of Exxon Corporation and the parent to FPE, reported to the the Commission that many FPE circuit breakers did not fully comply with Underwriters Laboratories, Inc. (UL) requirements. Commission testing confirmed that these breakers fail certain UL calibration test requirements. The Commission investigation focused primarily on 2 pole residential circuit breakers manufactured before Reliance acquired FPE in 1979.

To meet UL standards, residential circuit breakers must pass a number of so-called "calibration tests." The purpose of these tests is to determine whether the circuit breakers will hold the

--more--

current for which they are rated and also automatically open or "trip" (shut off the current) within specified time limits if over-loading of the circuit causes current levels in excess of the breaker's amperage rating. (Overloading can occur because a consumer plugs too many products into a circuit or due to the failure of a product or component connected to that circuit). While the Commission is concerned about the failure of these FPE breakers to meet UL calibration requirements, the Commission is unable at this time to link these failures to the development of a hazardous situation.

According to Reliance, failures of these FPE breakers to comply with certain UL calibration requirements do not create a hazard in the household environment. It is Reliance's position that FPE breakers will trip reliably at most overload levels unless the breakers have been operated in a repetitive, abusive manner that should not occur during residential use. Reliance maintains that, at those few overload levels where FPE breakers may fail to trip under realistic use conditions, currents will be too low to generate hazardous temperatures in household wiring. Reliance believes its position in this regard is supported by test data that it provided to the Commission.

The Commission staff believes that it currently has insufficient data to accept or refute Reliance's position.

The Commission staff estimates that it would cost several million dollars to gather the data necessary to assess fully whether those circuit breakers which are installed in homes but which may fail UL calibration tests present a risk to the public. Based on

the Commission's limited budget (\$34 million for fiscal year 1983), the known hazards the Commission has identified and must address (involving products of other manufacturers) and the uncertainty of the results of such a costly investigation, the Commission has decided not to commit further resources to its investigation of FPE's circuit breakers. However, despite its decision to close this particular investigation, the Commission will continue its investigation of circuit breakers generally. The Commission can reopen its investigation of FPE circuit breakers if further information warrants.

The Commission advises consumers to take certain safety precautions with all circuit breakers and fuses. Consumers should:

- Know your electrical circuit. Know which outlets and products are connected to each circuit.
- Never overload any electrical circuit by connecting too many products to the circuit. Be particularly careful not to connect several products that demand high current (such as heating appliances) to a low amperage circuit.
- Comply with local building codes in wiring or adding electrical circuits. Make sure the wiring and devices used in the circuit are connected to a circuit breaker or fuse of the proper size.
- Immediately disconnect any electrical product if problems develop. Have the product examined by a competent repair person.
- Investigate to determine why a fuse blows or circuit breaker trips. Do not simply replace the fuse or reset the breaker. If a fuse blows or breaker trips, it is often a warning that

the circuit is overloaded. Check the circuit for causes of overloading (for example, too many appliances plugged in, a malfunctioning product, a short circuit). When in doubt, consult a licensed electrician.

Consumers who have questions concerning circuit breakers, or who wish to report information relating to their safety, may call the U.S. Consumer Product Safety Commission's toll-free safety hotline at 800-638-CPSC, teletypewriter for the hearing impaired at 800-638-8270 (Maryland only 800-492-8104).

#