

FORM FOR PROPOSALS FOR 2008 NATIONAL ELECTRICAL CODE®

INSTRUCTIONS – PLEASE READ CAREFULLY

Type or print legibly in black ink. Use a separate copy for each proposal. Limit each proposal to a SINGLE section. All proposals must be received by NFPA by 5 p.m., EST, Friday, November 4, 2005, to be considered for the 2008 National Electrical Code. Proposals received after 5:00 p.m., EST, Friday, November 4, 2005, will be returned to the submitter. If supplementary material (photographs, diagrams, reports, etc.) is included, you may be required to submit sufficient copies for all members and alternates of the technical committee.

LOG #

Date Rec'd:

Office Use Only

Please indicate in which format you wish to receive your ROP/ROC electronic paper download
(Note: In choosing the download option you intend to view the ROP/ROC from our Website, no copy will be sent to you.)

Date 10/26/05 Name Doug Lee* Tel. No. (301)504-7569

Company U.S. Consumer Product Safety Commission

Street Address 4330 East West Hwy City Bethesda State Md Zip 20814

Please Indicate Organization Represented (if any) U.S. Consumer Product Safety Commission

1. Section/Paragraph 210.12(A)

2. Proposal recommends (check one): new text revised text deleted text

3. Proposal (include proposed new wording, or identification of wording to be deleted):

(See attached Proposal)

4. Statement of Problem and Substantiation for Proposal:

(See attached Statement of Problem and Substantiation for Proposal)

5. This Proposal is original material (Note: Original material is considered to be the submitter's own idea based on or as a result of his/her own experience, thought or research and, to the best of his/her knowledge, is not copied from another source.)

This Proposal is not original material, its source (if known) is as follows: _____

* This proposal is that of the CPSC staff, has not been reviewed or approved by, and may not necessarily reflect the views of, the Commission.

I hereby grant the NFPA all and full rights in copyright, in this proposal, and I understand that I acquire no rights in any publication of NFPA in which this proposal in this or another similar or analogous form is used.

Pursuant to 17 U.S.C. Sec. 105, I cannot transfer copyright rights to work of the U.S. Government. However, since there is no copyright in works of the U.S. Government, you and other members of the public may use the material for any purpose.

Signature (Required)

Mail to: Secretary, Standards Council, National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101
Quincy, MA 02269 or FAX to 617-770-3500

Proposal for 210.12 (A)

Revise section 210.12 (A) to read as follows:

(A) Definition: Arc-Fault Circuit Interrupter (AFCI). An arc-fault circuit interrupter is a device intended to provide protection from the effects of arc faults by recognizing characteristics unique to arcing and by functioning to de-energize the circuit when an arc fault is detected.

Statement of Problem and Substantiation for Proposal:

The acronym "AFCI" is used in 210.12(B) but is not previously defined. Appropriately, the acronym "GFCI" is in the definition of Ground-Fault Circuit Interrupter (GFCI) in article 100.

Some people are still confused by arc-fault circuit interrupters, which are used to protect against arcing faults to prevent fires, and ground-fault circuit interrupters, which are used for personnel protection against electrical shock. This addition will help users to relate arc-fault circuit interrupter to AFCI.

Submitter: Doug Lee, U.S. Consumer Product Safety Commission Staff*