

PURAFIL ENVIRONMENTAL CORROSION REPORT

22-Oct-2010

Company: 115707

Sales Order #: C002697

CCC Panel #: P67966

Date In: 23-Sep-2010

Date Out: 07-Oct-2010

Days In Service: 14

Room Area ID: Supply

Reference #:

115707

DO NOT TOUCH METAL COUPON

Corrosion Classification Coupon

Company	
Address	
Room/Area I.D. <i>Supply</i>	
Date In <i>9/23/10</i>	Time In: <i>16:45</i> a.m. p.m.
Date Out <i>10/7/10</i>	Time Out: <i>9:40</i> a.m. p.m.
Coupon # <i>67966</i>	Tracking # <i>02697</i>
Serial #	

Industrial
 ERM
 Preservation
 CIF

PURAFIL
 First...in clean air

2654 Weaver Way • Doraville, Georgia 30340
 Ph: (770) 662-8545 • (800) 222-6367
 Fx: (770) 263-6922 • www.purafil.com

CCC Panel # P67966
ISA Class G2
Moderate

Copper Corrosion
307 Å/30 Days
Silver Corrosion
395 Å/30 Days

(see next page for complete analysis)

Summary for PURAFIL CCC # P67966

The electrolytic reduction analysis on Corrosion Classification Coupon #P67966 shows the presence of moderate concentrations of contaminants in the environment tested. The hydrogen sulfide level is expected to range between 3 and 10 ppb and the sulfur dioxide level between 10 and 100 ppb. The effects of corrosion are measurable and may be a factor in determining equipment reliability.

Your local representative for additional information and assistance is:
 Environmental Health and Eng
 117 Fourth Avenue, Needham MA 02494, USA
 tminegishi@eheinc.com

Purafil, Inc. / 2654 Weaver Way, Doraville GA 30340 USA / (770) 662-8545 / (770) 263-6922
 Email: purafil@purafil.com / Internet: http://www.purafil.com

Displaying Page 1 [Display Page 2](#)

PURAFIL CCC # P67966 Analysis Results

Corrosion Film Composition				Gold Coupon - Magnified 20x
	Projections			
	<u>30 Days</u>	<u>1 Year</u>	<u>5 Year</u>	
Copper Films				
Cu ₂ S	0 Å	0 Å	0 Å	
Cu ₂ O	202 Å	270 Å	353 Å	
Unknowns	105 Å	140 Å	183 Å	
Totals	307 Å	410 Å	536 Å	
Silver Films				
AgCl	0 Å	0 Å	0 Å	
Ag ₂ S	395 Å	4807 Å	24036 Å	
Unknowns	0 Å	0 Å	0 Å	
Totals	395 Å	4807 Å	24036 Å	

Gold Pore Corrosion:
 Note: 1000 Å = 0.1 micron

Equipment Reliability Correlation
 (ISA Standard S71.04-1985 for Copper)

